

Test Certificate n°

**14CN0034**

-“FABRIC FIJI”.

According with the customer information:  
99% cotton/ 1% Antistatic, 220gsm twill 2/1  
FR Code: 99C/1AS-220FR-T  
Colour: Grey  
Part Number: FRL-01-LKWD

Shanghai XM Group LTD

Room 2403,88 Guangxin Road  
CN-200063 Shanghai

**UNE-EN 61482-1-2:2008+ERRATUM:2008 equivalent to IEC 61482-1-2:2007. Protective clothing against the thermal hazards of an electric arc.**

4.1 Live working –Protective clothing against the thermal hazards of an electric arc –Part 1-2: Test methods - Method 2: Determination of arc protection class of material and clothing by using a constrained and directed arc (box test) - Class 1

The test results above indicated, are shown in the testing report/s:

**2014CN0034**

Issued by AITEX

This document is of application for the tested sample, according to the tests that have been done in the previously mentioned dates in the reports above shown.

This does not imply any monitoring or control activity on this product done by AITEX.



Signed by Raquel Muñoz González  
Chief of laboratories Area 2

06/03/2014